

Maryborough Retic data (Jun 2014 - Jun 2015)	Manganese	Copper	Escherichia Chlorine	Free Chlorine	Aluminium	Iron	pH	Total Hardness	True Colour	Turbidity	Zinc
Result (max/min)	0.072	1.07	<1	4.8/0.02	0.054	0.134	8.6/6.5	75	5	1.1	0.172
Guideline value, ADWG (2004)	0.5mg/L	2mg/L	Zero in 100mL	5mg/L	0.2mg/L	0.3mg/L	6.5 - 8.5	60 - 200 acceptable	<15 TCU	<5 NTU	3mg/L
95th percentile	<0.01	0.08	<1	2.5	0.036	0.041	8	68	0	0.524	0.027
Number of samples tested	312	312	623	623	312	312	312	312	312	312	312
Number of exceedances of guideline value	0	0	0	0	0	0	0	0	0	0	0
% Compliance with ADWG	100%	100%	100%	100%	100%	100%	99%	N/A	100%	99.83%	100%