

Tiaro Retic data (Jun 2014 - Jun 2015)	Manganese	Copper	Escherichia Chlorine	Free Chlorine	Aluminium	Iron	pH	Total Hardness	True Colour	Turbidity	Zinc
Result (max/min)	0.124	0.011	<1	2.4/0.91	0.282	0.26	8.5/7.1	175	<0	12.3	0.023
Guideline value, ADWG (2004)	0.5mg/L	2mg/L	Zero in 100mL	5mg/L	0.2mg/L	0.3mg/L	6.5 - 8.5	60 - 200 acceptable	<15 TCU	<5 NTU	3mg/L
95th percentile	0.023	<0.01	<1	1.85	0.123	0.026	8.06	171.95	0	0.987	0.022
Number of samples tested	48	48	48	48	48	48	48	48	48	48	48
Number of exceedances of guideline value	0	0	0	0	1	0	0	0	0	0	0
% Compliance with ADWG	100%	100%	100%	100%	98%	100%	99%	N/A	100%	97.91%	100%