


## FCRC – SEWER/STORMWATER CCTV DIGITAL SUBMISSION GUIDELINES

An acceptable sewer or stormwater CCTV digital submission to FCRC should use the following guidelines.

Software: Wincan VX or earlier, Light Viewer (or similar)

There will be a project folder which will contain several subfolders. The project folder name should be no more than 50 characters in length. DB, Picture and Video subfolders will always be found in a valid project folder as below:



- DB – will contain a database file with a list of all individual surveys undertaken.
  - For easy identification, each survey in the database should use the Start Manhole & End Manhole format used in the as constructed or approved design drawings (e.g., 3/3 – 2/3).

S_SurveyDate	Original Start Manhole	Original End Manhole
19/04/2024	3/3	2/3
19/04/2024	2/3	1/3

- Valid database files extensions are:
    - mdb
    - db3
    - sdf
- Picture – will contain relevant photos from each survey.
  - Photos should be provided for all house connections, defects and other noteworthy features. All picture files will be:
    - jpg
- Video – will contain movie files.
  - Individual video files represent each section of pipe from node to node (manhole, inspection opening, end cap).
  - Valid video file extensions are:
    - mpg
    - mp4
    - avi

Contractor or Engineers should make CCTV surveys available by USB delivery to the Development Team at the FCRC office in Tavistock St or via download link. Please ensure each folder/subfolder has all the required information in it (i.e, DB folder has a database file, Video & Picture folders have the same number of video and/or picture files as the originating location).